

**ALL SMOKE ALARMS SHALL BE CEILING MOUNTED**

	YEAR BUILT or SUBSTANTIALLY MODIFIED				
	Before 1975	1975 - 8/27/97	8/27/97 - 2007	1/08 - 2/11	2/11 - Present
<b>SMOKE ALARM POWER =</b>	BATTERY or HARDWIRED	HARDWIRED, INTERCONNECTED	HARDWIRED, INTERCONNECTED W/ BATTERY B/U	HARDWIRED, INTERCONNECTED W/ BATTERY B/U	HARDWIRED, INTERCONNECTED W/ BATTERY B/U

**TYPE OF SMOKE ALARM ( Photoelectric or Ionization)**

On the same level, If a required detector is <b>More Than 20 ft.</b> from a kitchen or full bathroom doorway it shall be:	Either: a <b>Dual Detector*</b> OR One Photoelectric <b>AND</b> One Ionization alarm	Photoelectric <b>OR</b> Ionization	Photoelectric <b>OR</b> Ionization	Photoelectric <b>OR</b> Dual Detector*	Photoelectric Only
On the same level, If a required detector is <b>Within 20 ft.</b> of kitchen or full bathroom doorway it shall be:	Photoelectric Only	Photoelectric <b>OR</b> Ionization	Photoelectric Only	Photoelectric Only	Photoelectric Only

**Carbon Monoxide detectors:**

Shall be located on each habitable level including; in the hallway Outside each separate Sleeping Area (bedrooms), no farther than 10 ft. from any bedroom door.

**Carbon Monoxide (CO) Alarm Power Supply**

Battery or Plug-In w/battery backup	Allowed	Allowed	Allowed	NOT Allowed	NOT Allowed
Hardwired, interconnected w/battery backup	Allowed	Allowed	Allowed	Required	Required

<b>Alarm Locations</b>					
Finished Basement at base of stairs	Smoke & CO	Smoke & CO	Smoke & CO	Smoke & CO	Smoke & CO
Unfinished Basement	Smoke	Smoke	Smoke	Smoke & CO	Smoke & CO
Base of Stairs leading to Occupied floor above	Smoke	Smoke	Smoke	Smoke	Smoke
Outside each Sleeping Area (in hallway)	Smoke & CO	Smoke & CO	Smoke & CO	Smoke & CO	Smoke & CO
Inside every Bedroom			Smoke	Smoke	Smoke
Finished Attic (Habitable)	Smoke & CO	Smoke & CO	Smoke & CO	Smoke & CO	Smoke & CO
Garage (Attached)				Heat Detector	Heat Detector

**\*A Dual Detector consists of one detector with both photoelectric and ionization technology**

**One Smoke Alarm is needed for each 1,200 square feet of area, per floor**

**Low Voltage fire warning systems are exempt from the dual detector technology requirement**

**Combination Smoke and Carbon Monoxide Alarms MUST have a Voice Feature**