

# Energy Code Duct Tightness Verification

Pass/Fail

Date:

Permit No.:

Street Address:

Total conditioned floor area (sq. ft.):

Source of area and volume calculations:

Builder \_\_\_\_\_ Tester \_\_\_\_\_ Other \_\_\_\_\_

Tester:	
Signature:	
Builder:	
Builder Contact:	
HVAC Contractor:	

## Post-construction test

Total Leakage – 4.0 cfm/100 ft<sup>2</sup> maximum allowed

Testing result: \_\_\_\_\_ cfm/100 ft<sup>2</sup>

## Rough-in test

### Total leakage

Air Handler Installed?

Yes – 4 cfm/100 ft<sup>2</sup> maximum allowed

No – 3 cfm/100 ft<sup>2</sup> maximum allowed

Testing result: \_\_\_\_\_ cfm/100 ft<sup>2</sup>

Comments:

Results apply to the system as tested on the date above. Compliance is void if any changes are made to the duct system.