

LYNCO FIRE PROTECTION INC.

CONTRACTORS – ENGINEERS – INSTALLATION

SALES – REPAIRS – INSPECTIONS

19 GRANT AVENUE, BURLINGTON, MA 01803
TEL. (781) 221 – 0111 FAX. (781) 229 – 8323

HYDRANT FLOW TEST

JOB:	Prescott Apartments	WATER DEP. CONTACT:	Peter Isbell
ADDRESS:	2 Prescott St	TELEPHONE #:	781-858-1848
CITY/TOWN:	Reading, MA.	FAX:	
CONTACT:	Peter Isbell	FEE:	\$0 Due
DATE:	10/26/16	Time:	10:00 pm

STATI 80 PSI RESIDUAL: 72 PSI GPM: 1250

NOTES: SIZE OF MAIN = ?

