

Reading Schools 2016 LCCA Lead in Water Testing Results

MassDEP & EPA Action Level (AL) for Lead in water is: >15 ug/L (15ppb)

Coolidge Middle School				Updated 07/05/16				
School	Location	Fixture Type	Fixture ID #	05/19/16 First Draw ug/L	06/03/16 First Draw ug/L	06/03/16 30 Sec Flush ug/L	06/20/16 First Draw ug/L	06/20/16 30 Sec Flush ug/L
Coolidge	Room A1	Sink	CMS-00A1-SK1	3.65			4.52	
Coolidge	Room A2	Sink	CMS-00A2-SK1				8.09	
Coolidge	Room C1	Sink	CMS-00C1-SK1				Not Detected	
Coolidge	In Hall by Room C7	Water Fountain	CMS-00C7-WF1				Not Detected	
Coolidge	In Hall by Room C7	Water Fountain	CMS-00C7-WF2				Not Detected	
Coolidge	Room D7	Sink	CMS-00D7-SK1	4.50			4.44	
Coolidge	In Hall by Room D7	Water Fountain	CMS-00D7-WF1				Not Detected	
Coolidge	In Hall by Room D7	Water Fountain	CMS-00D7-WF2				Not Detected	
Coolidge	Room E1	Sink	CMS-00E1-SK1				5.81	
Coolidge	Room E2	Sink	CMS-00E2-SK1				23.50	4.75
Coolidge	Room F6	Sink	CMS-00F6-SK1				2.90	
Coolidge	Room F6	Sink	CMS-00F6-SK2				32.40	Not Detected
Coolidge	Room F7	Sink	CMS-00F7-SK1	4.04			6.39	
Coolidge	In Hall by Room A2	Water Fountain	CMS-A2HL-WF1				Not Detected	
Coolidge	In Hall by Room A2	Water Fountain	CMS-A2HL-WF2				Not Detected	
Coolidge	Adult Bath by Room C5	Sink	CMS-ADLT-SK1				12.50	
Coolidge	Adult Bath by Room C7	Sink	CMS-ADLT-SK2				12.40	
Coolidge	Room B200	Sink	CMS-B200-SK1	Not Detected			3.32	
Coolidge	In Hall by Room B700	Water Fountain	CMS-B700-WF1	Not Detected			Not Detected	
Coolidge	In Hall by Room B700	Water Fountain	CMS-B700-WF2				Not Detected	
Coolidge	Boys Bath by Room B8	Sink	CMS-B8BT-SK1				Not Detected	
Coolidge	Boys Bath by Room B8	Sink	CMS-B8BT-SK2				3.32	
Coolidge	Girls Bath by Room B8	Sink	CMS-B8GT-SK1				Not Detected	
Coolidge	Girls Bath by Room B8	Sink	CMS-B8GT-SK2				Not Detected	
Coolidge	Boys Bath by Room C5	Sink	CMS-BHL2-SK1				23.00	4.13
Coolidge	Boys Bath by Room C5	Sink	CMS-BHL2-SK2				1.10	
Coolidge	Boys Locker Room	Sink	CMS-BLKR-SK1				2.60	
Coolidge	Boys Locker Room	Shower	CMS-BLKR-SS1				12.20	
Coolidge	Boys Locker Room	Shower	CMS-BLKR-SS2				3.10	
Coolidge	Boys Locker Room	Shower	CMS-BLKR-SS3				28.10	5.83
Coolidge	Boys Locker Room	Shower	CMS-BLKR-SS4				12.20	
Coolidge	Cafeteria	Water Fountain	CMS-CAFE-WF1	Not Detected			Not Detected	

Coolidge	Cafeteria	Water Fountain	CMS-CAFE-WF2				Not Detected	
Coolidge	Boys Bath by Cafeteria	Sink	CMS-CFBB-SK1				Not Detected	
Coolidge	Boys Bath by Cafeteria	Sink	CMS-CFBB-SK2				Not Detected	
Coolidge	Girls Bath by Cafeteria	Sink	CMS-CFGB-SK1				Not Detected	
Coolidge	Girls Bath by Cafeteria	Sink	CMS-CFGB-SK2				Not Detected	
Coolidge	In Hall by Room D202	Water Fountain	CMS-D202-WF1				Not Detected	
Coolidge	In Hall by Room D202	Water Fountain	CMS-D202-WF2				Not Detected	
Coolidge	Girls Bath by Room C7	Sink	CMS-GHL2-SK1				Not Detected	
Coolidge	Girls Bath by Room C7	Sink	CMS-GHL2-SK2				4.34	
Coolidge	Girls Locker Room	Sink	CMS-GLKR-SK1				1.17	
Coolidge	Girls Locker Room	Sink	CMS-GLKR-SK2				Not Detected	
Coolidge	Girls Locker Room	Sink	CMS-GLKR-SK3				Not Detected	
Coolidge	Girls Locker Room	Shower	CMS-GLKR-SS1				80.60	5.59
Coolidge	Girls Locker Room	Shower	CMS-GLKR-SS2				105.00	6.2
Coolidge	Girls Locker Room	Shower	CMS-GLKR-SS3				9.62	
Coolidge	Girls Locker Room	Shower	CMS-GLKR-SS4				18.20	5.63
Coolidge	Girls Locker Room	Shower	CMS-GLKR-SS5				19.10	5.46
Coolidge	Gymnasium	Water Fountain	CMS-GYMN-WF1				Not Detected	
Coolidge	Kitchen	Cooking Kettle 1	CMS-KICH-KT1		17.10	Not Detected	2.97	
Coolidge	Kitchen	Cooking Kettle 2	CMS-KICH-KT2		2.98		15.40	4.62
Coolidge	Kitchen	Kitchen Dish-Wash Sprayer	CMS-KICH-SK1		1.42		Not Detected	
Coolidge	Kitchen	Kitchen Food Prep Sink	CMS-KICH-SK2		5.37		5.85	
Coolidge	Kitchen	Kitchen Hand Wash Sink	CMS-KICH-SK3	69.77	22.30	1.78	10.80	
Coolidge	Kitchen	Kitchen Food Prep Sink	CMS-KICH-SK4		2.92		3.21	
Coolidge	Kitchen Workers Bath	Sink	CMS-KICH-SKB				12.50	
Coolidge	Adult Mens Teachers Bath	Sink	CMS-MNBT-SK1				Not Detected	
Coolidge	Nurse Office	Sink	CMS-NRSE-SK1				6.13	
Coolidge	Nurse Bath	Sink	CMS-NRSE-SK2				Not Detected	
Coolidge	Main Office	Sink	CMS-OFCE-SK1				1.70	
Coolidge	Adult Mens Teachers Bath	Sink	CMS-TCHM-SK1				1.03	
Coolidge	Adult Womens Teachers Bath	Sink	CMS-TCHW-SK1				Not Detected	
Coolidge	Adult Womens Teachers Bath	Sink	CMS-WNBT-SK1				Not Detected	
Coolidge	Adult Womens Teachers Bath	Sink	CMS-WNBT-SK2				Not Detected	