

# Reading Public Buildings 2016 Lead in Water Testing Results

MassDEP & EPA Action Level (AL) for Lead in water is: >15 ug/L (15ppb)

<b>Reading Public Town Buildings</b>				<b>Updated 07/15/16</b>		
<b>Building</b>	<b>Location</b>	<b>Fixture Type</b>	<b>Fixture ID #</b>	<b>06/21/16 First Draw ug/L</b>	<b>06/21/16 30 Sec Flush ug/L</b>	
Reading DPW	In Hall by Lunch Room	Water Fountain	DPW-HALL-WF1	Not Detected		
Reading DPW	Men's Bathroom	Sink Faucet	DPW-MBAT-SK1	3.87		
Reading DPW	Men's Bathroom	Sink Faucet	DPW-MBAT-SK2	3.21		
Reading DPW	Women's Bathroom	Sink Faucet	DPW-WBAT-SK1	Not Detected		
Reading Fire Station (Main St)	Men's Garage Bay Bathroom	Sink Faucet	FRM-BAYB-SK1	Not Detected		
Reading Fire Station (Main St)	Handicap Bathroom	Sink Faucet	FRM-HBTH-SK1	Not Detected		
Reading Fire Station (Main St)	Kitchen	Sink Faucet	FRM-KICH-SK1	1.08		
Reading Fire Station (Main St)	Men's Bathroom	Sink Faucet	FRM-MBTH-SK1	Not Detected		
Reading Fire Station (Main St)	Women's Bathroom	Sink Faucet	FRM-WBTH-SK1	5.87		
Reading Fire Station (Woburn St)	Kitchen	Sink Faucet	FRW-KICH-SK1	3.30		
Reading Fire Station (Woburn St)	Men's Bathroom	Sink Faucet	FRW-MBAT-SK1	11.90	2.12	
Reading Fire Station (Woburn St)	Women's Bathroom	Sink Faucet	FRW-WBAT-SK1	2.95		
Reading Fire Station(Woburn St)	Men's Garage Bay Bathroom	Sink Faucet	FRW-BAYB-SK1	<b>51.50</b>	4.01	
Reading Police Station	1st Floor Men's Bathroom	Sink Faucet	PLC-1HAL-SK1	Not Detected		
Reading Police Station	1st Floor Women's Bathroom	Sink Faucet	PLC-1HAL-SK2	1.13		
Reading Police Station	2nd Floor Hallway	Water Fountain	PLC-2NFL-WF1	Not Detected		
Reading Police Station	Basement Hallway	Water Fountain	PLC-BHAL-WF1	Not Detected		
Reading Police Station	Communication's Room #2	Sink Faucet	PLC-CRM2-SK1	10.10		
Reading Police Station	Dispatch Bathroom	Sink Faucet	PLC-DSPC-SK1	1.80		
Reading Police Station	Dispatch Kitchenette	Sink Faucet	PLC-DSPC-SK2	Not Detected		
Reading Police Station	Kitchen	Sink Faucet	PLC-KICH-SK1	1.23		
Reading Police Station	Lobby	Water Fountain	PLC-LOBY-WF1	Not Detected		
Reading Police Station	2nd Floor Men's Bathroom	Sink Faucet	PLC-MB2F-SK1	1.99		
Reading Police Station	Lobby Men's Bathroom	Sink Faucet	PLC-MBLB-SK1	2.75		
Reading Police Station	Men's Fitness Room	Sink Faucet	PLC-MFIT-SK1	6.29		
Reading Police Station	2nd Floor Women's Bathroom	Sink Faucet	PLC-WB2F-SK1	Not Detected		
Reading Police Station	Lobby Women's Bathroom	Sink Faucet	PLC-WBLB-SK1	1.93		
Reading Police Station	Women's Fitness Room	Sink Faucet	PLC-WFIT-SK1	7.13		

