

Reading Schools 2016 LCCA Lead in Water Testing Results

03 of 11

MassDEP Action Level (AL) for Lead in water is: Greater Than 15 ug/L (Reading set an AL of 12 ug/L)

MassDEP Action Level (AL) for Copper in water is: Greater Than 1300 ug/L (No Sample has ever exceeded or come close to the Copper Action Level in Reading Schools)

ND = Not Detected or Less Than 1 ug/L (< 1 ppb)

03_Coolidge Middle School

ESE Code #: 02460305

Lead Levels Found in School Tap Samples Updated 08/30/16

School	Location	Fixture Type	Fixture ID #	DEP #	05/19/16 First Draw ug/L	06/20/16 First Draw ug/L	06/20/16 30 Sec Flush ug/L	08/07/16 Remediation	08/08/16 First Draw ug/L	08/08/16 30 Sec Flush ug/L	08/23/16 First Draw ug/L	08/23/16 30 Sec Flush ug/L	08/30/16 Remediation
Coolidge Middle School	Gymnasium	Water Fountain	CMS-GYMN-WF1	001		ND	ND						
Coolidge Middle School	Boys Locker Room	Shower	CMS-BLKR-SS2	002		3.1	ND						
Coolidge Middle School	Boys Locker Room	Shower	CMS-BLKR-SS3	003		28.1	5.8	Disconnected					
Coolidge Middle School	Boys Locker Room	Shower	CMS-BLKR-SS1	004		12.2	ND	Disconnected					
Coolidge Middle School	Boys Locker Room	Shower	CMS-BLKR-SS4	005		12.2	ND	Disconnected					
Coolidge Middle School	Boys Locker Room	Sink	CMS-BLKR-SK1	006		2.6	ND						
Coolidge Middle School	Girls Locker Room	Shower	CMS-GLKR-SS3	007		9.6	ND						
Coolidge Middle School	Girls Locker Room	Shower	CMS-GLKR-SS4	008		18.2	5.6	Disconnected					
Coolidge Middle School	Girls Locker Room	Shower	CMS-GLKR-SS5	009		19.1	5.5	Disconnected					
Coolidge Middle School	Kitchen Workers Bath	Sink	CMS-KICH-SKB	010		12.5	ND	Replace Faucet	26.9	ND	15.2	1.7	Post "Hand Wash Only"
Coolidge Middle School	Kitchen	Kitchen Hand Wash Sink	CMS-KICH-SK3	011	69.8	10.8	ND	Replace Faucet	6.8	ND			
Coolidge Middle School	Kitchen	Kitchen Food Prep Sink	CMS-KICH-SK4	012		3.2	ND						
Coolidge Middle School	Kitchen	Cooking Kettle 1	CMS-KICH-KT1	013		3.0	ND	Replace Fixture	19.7	ND	36.3	2.8	Post "Flush 30 Sec"
Coolidge Middle School	Kitchen	Cooking Kettle 2	CMS-KICH-KT2	014		15.4	4.6	Replace Fixture	16.5	ND	23.5	1.8	Post "Flush 30 Sec"
Coolidge Middle School	Kitchen	Kitchen Food Prep Sink	CMS-KICH-SK2	015		5.9	ND						
Coolidge Middle School	Kitchen	Kitchen Wash Sprayer	CMS-KICH-SK1	016		ND	ND						
Coolidge Middle School	Cafeteria	Water Fountain	CMS-CAFE-WF2	017		ND	ND						
Coolidge Middle School	Cafeteria	Water Fountain	CMS-CAFE-WF1	018	ND	ND	ND						
Coolidge Middle School	Girls Bath by Cafeteria	Sink	CMS-CFGB-SK1	019		ND	ND						
Coolidge Middle School	Girls Bath by Cafeteria	Sink	CMS-CFGB-SK2	020		ND	ND						
Coolidge Middle School	Girls Locker Room	Sink	CMS-GLKR-SK1	021		1.2	ND						
Coolidge Middle School	Girls Locker Room	Sink	CMS-GLKR-SK2	022		ND	ND						
Coolidge Middle School	Girls Locker Room	Sink	CMS-GLKR-SK3	023		ND	ND						
Coolidge Middle School	Girls Locker Room	Shower	CMS-GLKR-SS1	024		80.6	5.6	Disconnected					
Coolidge Middle School	Girls Locker Room	Shower	CMS-GLKR-SS2	025		105.0	6.2	Disconnected					
Coolidge Middle School	Adult Mens Teachers Bath	Sink	CMS-TCHM-SK1	026		1.0	ND						
Coolidge Middle School	Adult Womens Teachers Bath	Sink	CMS-TCHW-SK1	027		ND	ND						
Coolidge Middle School	Adult Womens Teachers Bath	Sink	CMS-WNBT-SK1	028		ND	ND						
Coolidge Middle School	Adult Womens Teachers Bath	Sink	CMS-WNBT-SK2	029		ND	ND						
Coolidge Middle School	Adult Mens Teachers Bath	Sink	CMS-MNBT-SK1	030		ND	ND						
Coolidge Middle School	Boys Bath by Cafeteria	Sink	CMS-CFBB-SK2	031		ND	ND						
Coolidge Middle School	Boys Bath by Cafeteria	Sink	CMS-CFBB-SK1	032		ND	ND						
Coolidge Middle School	Room C1	Sink	CMS-00C1-SK1	033		ND	ND						
Coolidge Middle School	In Hall by Room D7	Water Fountain	CMS-00D7-WF2	034		ND	ND						
Coolidge Middle School	Adult Bath by Room C5	Sink	CMS-ADLT-SK1	035		12.5	ND	Replace Faucet	ND	ND			
Coolidge Middle School	Room D7	Sink	CMS-00D7-SK1	036	4.5	4.4	ND						
Coolidge Middle School	Girls Bath by Room C7	Sink	CMS-GHL2-SK1	037		ND	ND						
Coolidge Middle School	Girls Bath by Room C7	Sink	CMS-GHL2-SK2	038		4.3	ND						
Coolidge Middle School	Room B200	Sink	CMS-B200-SK1	039	ND	3.3	ND						
Coolidge Middle School	In Hall by Room D202	Water Fountain	CMS-D202-WF1	040		ND	ND						
Coolidge Middle School	In Hall by Room D202	Water Fountain	CMS-D202-WF2	041		ND	ND						
Coolidge Middle School	Nurse Bath	Sink	CMS-NRSE-SK2	042		ND	ND						
Coolidge Middle School	Nurse Office	Sink	CMS-NRSE-SK1	043		6.1	ND						
Coolidge Middle School	Main Office	Sink	CMS-OFCE-SK1	044		1.7	ND						
Coolidge Middle School	Room A1	Sink	CMS-00A1-SK1	045	3.7	4.5	ND						
Coolidge Middle School	Room A2	Sink	CMS-00A2-SK1	046		8.1	ND						
Coolidge Middle School	In Hall by Room A2	Water Fountain	CMS-A2HL-WF2	047		ND	ND						
Coolidge Middle School	In Hall by Room A2	Water Fountain	CMS-A2HL-WF1	048		ND	ND						
Coolidge Middle School	Room E1	Sink	CMS-00E1-SK1	049		5.8	ND						
Coolidge Middle School	Room E2	Sink	CMS-00E2-SK1	050		23.5	4.8	Replace Faucet	1.8	ND			
Coolidge Middle School	In Hall by Room B700	Water Fountain	CMS-B700-WF1	051	ND	ND	ND						
Coolidge Middle School	In Hall by Room B700	Water Fountain	CMS-B700-WF2	052		ND	ND						

Coolidge Middle School	Room F7	Sink	CMS-00F7-SK1	053	4.0	6.4	ND						
Coolidge Middle School	Boys Bath by Room B8	Sink	CMS-B8BT-SK1	054		ND	ND						
Coolidge Middle School	Boys Bath by Room B8	Sink	CMS-B8BT-SK2	055		3.3	ND						
Coolidge Middle School	Girls Bath by Room B8	Sink	CMS-B8GT-SK1	056		ND	ND						
Coolidge Middle School	Girls Bath by Room B8	Sink	CMS-B8GT-SK2	057		ND	ND						
Coolidge Middle School	Room F6	Sink	CMS-00F6-SK2	058		32.4	ND	Replace Faucet	3.3	ND			
Coolidge Middle School	Room F6	Sink	CMS-00F6-SK1	059		2.9	ND						
Coolidge Middle School	Boys Bath by Room C5	Sink	CMS-BHL2-SK2	060		1.1	ND						
Coolidge Middle School	Boys Bath by Room C5	Sink	CMS-BHL2-SK1	061		23.0	4.1	Replace Faucet	ND	ND			
Coolidge Middle School	Adult Bath by Room C7	Sink	CMS-ADLT-SK2	062		12.4	ND	Replace Faucet	ND	ND			
Coolidge Middle School	In Hall by Room C7	Water Fountain	CMS-00C7-WF2	063		ND	ND						
Coolidge Middle School	In Hall by Room C7	Water Fountain	CMS-00C7-WF1	064		ND	ND						
Coolidge Middle School	In Hall by Room D7	Water Fountain	CMS-00D7-WF1	065		ND	ND						