

Reading Schools 2019 LCCA Lead in Water Testing Results

MassDEP Action Level (AL) for Lead in water is: Greater Than 15 ug/L (Reading set an AL of 12 ug/L)

MassDEP Action Level (AL) for Copper in water is: Greater Than 1300 ug/L (No Sample has ever exceeded or come close to the Copper Action Level in Reading Schools)

ND = Not Detected or Less Than 1 ug/L (< 1 ppb)

04_Parker Middle School		ESE Code #: 02460310			Lead Levels Found in School Tap Samples Updated 08/13/19						
School	Location	Fixture Type	Fixture ID #	DEP #	05/19/16 First Draw ug/L	06/13/19 First Draw ug/L	06/13/19 30 Sec Flush ug/L	07/22/19 Remediation	07/24/19 First Draw ug/L	07/24/19 30 Sec Flush ug/L	08/13/19 Remediation
Parker Middle School	Hall by Rm 110	Water Fountain	PMS_H110_WF1	001	ND	ND	ND				
Parker Middle School	Bathroom 2 All Gender	Sink	PMS_BT2G_SK1	002		ND	ND				
Parker Middle School	Bathroom 3 All Gender	Sink	PMS_BT3G_SK1	003		7.8	ND				
Parker Middle School	School Kitchen	Sink	PMS_KTCH_SK4	004		2.9	ND				
Parker Middle School	School Kitchen	Sink	PMS_KTCH_SK5	005		5.8	ND				
Parker Middle School	School Kitchen	Sink	PMS_KTCH_SK6	006		ND	ND				
Parker Middle School	School Kitchen	Kettle	PMS_KTCH_KT1	007		19.3	ND	Replaced Faucet	4.0	ND	
Parker Middle School	School Kitchen	Kettle	PMS_KTCH_KT2	008		ND	ND				
Parker Middle School	Bathroom Kitchen	Sink	PMS_BTKT_SK1	009		ND	ND				
Parker Middle School	School Kitchen	Sink	PMS_KTCH_SK3	010		5.5	ND				
Parker Middle School	School Kitchen	Sink	PMS_KTCH_SK2	011		13.3	ND	Replaced Faucet	13.7	ND	TBD
Parker Middle School	School Kitchen	Sink	PMS_KTCH_SK1	012		3.7	1.4				
Parker Middle School	Bathroom 4 All Gender	Sink	PMS_BT4G_SK1	013		ND	ND				
Parker Middle School	Bathroom 5 All Gender	Sink	PMS_BT5G_SK1	014		ND	ND				
Parker Middle School	Hall by Rm 110	Water Fountain	PMS_H110_WF1	015		ND	ND				
Parker Middle School	Hall by Rm 110	Water Fountain	PMS_H110_WF2	016		ND	ND				
Parker Middle School	Nurse's Office	Sink	PMS_NRSE_SK2	017		ND	ND				
Parker Middle School	Nurse's Office	Sink	PMS_NRSE_SK1	018		48.4	1.1	Replaced Faucet	21.3	ND	TBD
Parker Middle School	Main Office	Sink	PMS_OFCE_SK1	019		2.9	ND				
Parker Middle School	Men's Bathroom 1	Sink	PMS_BT1M_SK1	020		1.3	ND				
Parker Middle School	Women's Bathroom 1	Sink	PMS_BT1W_SK1	021		ND	ND				
Parker Middle School	Teachers Room	Sink	PMS_TCHR_SK1	022		1.4	ND				
Parker Middle School	Hall by Rm 116	Water Fountain	PMS_H116_WF2	023	ND	ND	ND				
Parker Middle School	Hall by Rm 116	Water Fountain	PMS_H116_WF1	024		ND	ND				
Parker Middle School	Girl's Bathroom 1st Fl	Sink	PMS_BT1G_SK3	025		1.9	ND				
Parker Middle School	Girl's Bathroom 1st Fl	Sink	PMS_BT1G_SK2	026		1.1	ND				
Parker Middle School	Girl's Bathroom 1st Fl	Sink	PMS_BT1G_SK1	027		ND	ND				
Parker Middle School	Boy's Bathroom 1st Fl	Sink	PMS_BT1B_SK1	028		1.5	2.6				
Parker Middle School	Boy's Bathroom 1st Fl	Sink	PMS_BT1B_SK2	029		1.1	ND				
Parker Middle School	Boy's Bathroom 1st Fl	Sink	PMS_BT1B_SK3	030		ND	ND				
Parker Middle School	Hall by Rm 212	Water Fountain	PMS_H212_WF1	031	ND	ND	ND				
Parker Middle School	Men's Bathroom 2	Sink	PMS_BT7M_SK1	032		ND	ND				
Parker Middle School	Women's Bathroom 2	Sink	PMS_BT7W_SK1	033		ND	ND				
Parker Middle School	Hall by Auditorium	Water Fountain	PMS_HAUD_WF2	034	ND	ND	ND				
Parker Middle School	Hall by Auditorium	Water Fountain	PMS_HAUD_WF1	035		ND	ND				
Parker Middle School	Hall by Rm 200	Water Fountain	PMS_H200_WF1	036		ND	ND				
Parker Middle School	Library	Sink	PMS_LBRY_SK1	037		2.9	1.2				
Parker Middle School	Hall by Rm 220	Water Fountain	PMS_H220_WF1	038	ND	ND	ND				
Parker Middle School	Girl's Bathroom 2nd Fl	Sink	PMS_BT6G_SK3	039		ND	ND				

Parker Middle School	Girl's Bathroom 2nd Fl	Sink	PMS_BT6G_SK2	040		ND	ND			
Parker Middle School	Girl's Bathroom 2nd Fl	Sink	PMS_BT6G_SK1	041		ND	ND			
Parker Middle School	Boys's Bathroom 2nd Fl	Sink	PMS_BT6B_SK3	042		2.7	ND			
Parker Middle School	Boys's Bathroom 2nd Fl	Sink	PMS_BT6B_SK2	043		1.1	ND			
Parker Middle School	Boys's Bathroom 2nd Fl	Sink	PMS_BT6B_SK1	044		3.8	ND			
Parker Middle School	Multi-Purpose_Room	Sink	PMS_HMPR_WF1	045		ND	ND			
Parker Middle School	Multi-Purpose_Room	Sink	PMS_HMPR_WF2	046		ND	ND			
Parker Middle School	Gym Office Bathroom Men	Sink	PMS_GYMM_SK1	047		ND	ND			
Parker Middle School	Boys's Bathroom Basement	Sink	PMS_BT8B_SK1	048		6.1	ND			
Parker Middle School	Boys's Bathroom Basement	Sink	PMS_BT8B_SK2	049		1.3	ND			
Parker Middle School	Boys's Bathroom Basement	Sink	PMS_BT8B_SK3	050		2.7	ND			
Parker Middle School	Girl's Bathroom Basement	Sink	PMS_BT8G_SK1	051		2.2	ND			
Parker Middle School	Girl's Bathroom Basement	Sink	PMS_BT8G_SK2	052		1.3	ND			
Parker Middle School	Girl's Bathroom Basement	Sink	PMS_BT8G_SK3	053		ND	ND			
Parker Middle School	Gym Office Bath Women	Sink	PMS_GYMW_SK1	054		4.6	ND			
Parker Middle School	Hall by Gym	Water Fountain	PMS_HGYM_WF1	055	ND	ND	ND			
Parker Middle School	Hall by Gym	Water Fountain	PMS_HGYM_WF2	056		ND	ND			
Parker Middle School	Teacher's Bath Basement	Sink	PMS_BT9C_SK1	057		1.7	ND			