

# Reading Schools 2017 LCCA Lead in Water Testing Results

**MassDEP Action Level (AL) for Lead in water is: Greater Than 15 ug/L (Reading set an AL of 12 ug/L)**

**MassDEP Action Level (AL) for Copper in water is: Greater Than 1300 ug/L (No Sample has ever exceeded or come close to the Copper Action Level in Reading Schools)**

ND = Not Detected or Less Than 1 ug/L (< 1 ppb)

## 07\_Joshua Eaton Elementary

**ESE Code #: 02460010**

## Lead Levels Found in School Tap Samples Updated 07/13/17

School	Location	Fixture Type	Fixture ID #	DEP #	05/19/16 First Draw ug/L	06/15/17 First Draw ug/L	06/15/17 30 Sec Flush ug/L	07/11/17 Remediation	07/13/17 First Draw ug/L	07/13/17 30 Sec Flush ug/L
Joshua Eaton Elementary	Modular Classroom	Water Fountain	EAT-MOD1-WF1	001	ND	ND	ND			
Joshua Eaton Elementary	Modular Classroom	Water Fountain	EAT-MOD-WF2	002		ND	ND			
Joshua Eaton Elementary	Modular Classroom	Sink	EAT-MODT-SK1	003		ND	ND			
Joshua Eaton Elementary	Modular Classroom	Water Fountain	EAT-MOD2-WF1	004	ND	ND	ND			
Joshua Eaton Elementary	Modular Classroom	Water Fountain	EAT-MOD2-WF2	005		ND	ND			
Joshua Eaton Elementary	Modular Classroom	Sink	EAT-MOD1-SK1	006		ND	ND			
Joshua Eaton Elementary	Modular Classroom	Sink	EAT-MOD2-SK2	007		ND	ND			
Joshua Eaton Elementary	Room 19	Water Fountain	EAT-RM19-WF1	008		3.7	ND			
Joshua Eaton Elementary	Room 10	Sink	EAT-RM10-SK1	009		10.5	4.0			
Joshua Eaton Elementary	Room 19	Sink	EAT-RM19-SK2	010		ND	ND			
Joshua Eaton Elementary	Room 20	Sink	EAT-RM20-SK2	011	3.4	ND	ND			
Joshua Eaton Elementary	Room 20	Sink	EAT-RM20-SK1	012		7.3	4.6			
Joshua Eaton Elementary	Room 20	Water Fountain	EAT-RM20-WF1	013		5.3	2.0			
Joshua Eaton Elementary	Room 12	Sink	EAT-RM12-SK1	014	2.4	5.7	ND			
Joshua Eaton Elementary	Room 12	Water Fountain	EAT-RM12-WF1	015		ND	ND			
Joshua Eaton Elementary	Room 13	Sink	EAT-RM13-SK1	016		5.7	ND			
Joshua Eaton Elementary	Room 13	Water Fountain	EAT-RM13-WF1	017		ND	ND			
Joshua Eaton Elementary	Room 14	Sink	EAT-RM14-SK1	018		5.8	ND			
Joshua Eaton Elementary	Room 15	Sink	EAT-RM15-SK1	020		6.4	1.0			
Joshua Eaton Elementary	Room 15	Water Fountain	EAT-RM15-WF1	021	3.7	7.8	1.5			
Joshua Eaton Elementary	Room 16	Sink	EAT-RM16-SK1	022		3.8	ND			
Joshua Eaton Elementary	Room 16	Water Fountain	EAT-RM16-WF1	023		7.9	1.3			
Joshua Eaton Elementary	Room 11	Sink	EAT-RM11-SK1	024		10.7	ND			
Joshua Eaton Elementary	Room 11	Water Fountain	EAT-RM11-WF1	025		ND	ND			
Joshua Eaton Elementary	Room 10	Sink	EAT-RM10-SK1	026		3.6	ND			
Joshua Eaton Elementary	Room 10	Water Fountain	EAT-RM10-WF1	027		ND	ND			
Joshua Eaton Elementary	Hall by Door 8	Water Fountain	EAT-HLD8-WF2	028		ND	ND			
Joshua Eaton Elementary	Hall by Door 8	Water Fountain	EAT-HLD8-WF1	029		ND	ND			
Joshua Eaton Elementary	Room 17	Sink	EAT-RM17-SK1	030	2.4	2.9	ND			
Joshua Eaton Elementary	Room 17	Water Fountain	EAT-RM17-WF1	031		ND	ND			
Joshua Eaton Elementary	Room 18	Sink	EAT-RM18-SK1	032		7.3	ND			
Joshua Eaton Elementary	Room 18	Water Fountain	EAT-RM18-WF1	033		17.2	1.4	Replace Faucet	ND	ND
Joshua Eaton Elementary	Gymnasium	Water Fountain	EAT-GYMN-WF1	034		ND	ND			
Joshua Eaton Elementary	Gymnasium	Water Fountain	EAT-GYMN-WF2	035		ND	ND			
Joshua Eaton Elementary	Teachers Bathroom	Sink	EAT-TCHB-SK1	036		7.6	ND			
Joshua Eaton Elementary	Boy's Bathroom	Sink	EAT-BBTH-SK1	037		ND	ND			
Joshua Eaton Elementary	Boy's Bathroom	Sink	EAT-BBTH-SK2	038		1.2	ND			
Joshua Eaton Elementary	Boy's Bathroom	Sink	EAT-BBTH-SK3	039		ND	ND			

Joshua Eaton Elementary	Boy's Bathroom	Sink	EAT-BBTH-SK4	040		ND	ND			
Joshua Eaton Elementary	Girl's Bathroom	Sink	EAT-GBTH-SK1	041		37.0	ND	Replace Faucet	2.4	ND
Joshua Eaton Elementary	Girl's Bathroom	Sink	EAT-GBTH-SK2	042		ND	ND			
Joshua Eaton Elementary	Girl's Bathroom	Sink	EAT-GBTH-SK3	043		ND	ND			
Joshua Eaton Elementary	Girl's Bathroom	Sink	EAT-GBTH-SK4	044		ND	ND			
Joshua Eaton Elementary	Room 08	Sink	EAT-RM08-SK1	045		5.8	ND			
Joshua Eaton Elementary	Room 08	Water Fountain	EAT-RM08-WF1	046		ND	ND			
Joshua Eaton Elementary	Room 09	Sink	EAT-RM09-SK1	047		7.4	4.3			
Joshua Eaton Elementary	Room 09	Water Fountain	EAT-RM09-WF1	048	2.4	6.8	ND			
Joshua Eaton Elementary	Woman's Bathroom	Sink	EAT-WBT1-SK1	049		ND	ND			
Joshua Eaton Elementary	Men's Bathroom	Sink	EAT-MBT1-SK1	050		ND	ND			
Joshua Eaton Elementary	Nurse's Office	Sink	EAT-NRSE-SK1	051	1.7	3.1	ND			
Joshua Eaton Elementary	Nurse's Bathroom	Sink	EAT-NRSE-SK2	052		ND	ND			
Joshua Eaton Elementary	Teacher's Lunchroom	Sink	EAT-TCHL-SK1	053		ND	ND			
Joshua Eaton Elementary	Kitchen	Hand Wash Sink	EAT-KITC-SK4	054		4.5	ND			
Joshua Eaton Elementary	Kitchen	Sink	EAT-KITC-SK3	055		4.3	ND			
Joshua Eaton Elementary	Kitchen	Sink	EAT-KITC-SK2	056	2.7	3.5	ND			
Joshua Eaton Elementary	Kitchen	Dish Wash Sprayer	EAT-KITC-SK1	057		14.3	ND	Post "Wash Only"		
Joshua Eaton Elementary	Room 05	Sink	EAT-RM05-SK1	058		1.7	ND			
Joshua Eaton Elementary	Room 05	Water Fountain	EAT-RM05-WF1	059		ND	ND			
Joshua Eaton Elementary	Room 04	Water Fountain	EAT-RM04-WF1	060		9.3	1.4			
Joshua Eaton Elementary	Room 04	Sink	EAT-RM04-SK1	061	ND	ND	ND			
Joshua Eaton Elementary	Room 03	Sink	EAT-RM03-SK1	062		9.4	ND			
Joshua Eaton Elementary	Room 03	Water Fountain	EAT-RM03-WF1	063		ND	ND			
Joshua Eaton Elementary	Room 02	Water Fountain	EAT-RM02-WF1	064		ND	ND			
Joshua Eaton Elementary	Room 02	Sink	EAT-RM02-SK1	065		4.8	ND			
Joshua Eaton Elementary	Room 01	Water Fountain	EAT-RM01-WF1	066		ND	ND			
Joshua Eaton Elementary	Room 01	Sink	EAT-RM01-SK1	067	2.8	1.9	ND			
Joshua Eaton Elementary	Room 06	Sink	EAT-RM06-SK1	068		ND	ND			
Joshua Eaton Elementary	Room 06	Sink	EAT-RM06-SK1	069		ND	ND			
Joshua Eaton Elementary	Room 22	Sink	EAT-RM22-SK1	070		3.4	ND			
Joshua Eaton Elementary	Room 22	Water Fountain	EAT-RM22-WF1	071		ND	ND			
Joshua Eaton Elementary	Room 23	Sink	EAT-RM23-SK1	072		2.7	2.5			
Joshua Eaton Elementary	Room 23	Water Fountain	EAT-RM23-WF1	073	3.7	16.0	ND	Replace Faucet	3.9	ND
Joshua Eaton Elementary	Room 24	Water Fountain	EAT-RM24-WF1	074		ND	ND			
Joshua Eaton Elementary	Room 24	Sink	EAT-RM24-SK1	075		6.6	ND			
Joshua Eaton Elementary	Room 21	Sink	EAT-RM21-SK1	076		ND	ND			
Joshua Eaton Elementary	Library	Water Fountain	EAT-LIBY_WF1	077		ND	ND			
Joshua Eaton Elementary	Caffeteria	Water Fountain	EAT-CAFE-WF1	078		ND	ND			
Joshua Eaton Elementary	Caffeteria	Water Fountain	EAT-CAFE-WF2	079		ND	ND			