

Reading Public Buildings 2016 LCCA Lead in Water Testing Results

10 of 11

MassDEP Action Level (AL) for Lead in water is: Greater Than 15 ug/L (Reading set an AL of 12 ug/L)

MassDEP Action Level (AL) for Copper in water is: Greater Than 1300 ug/L (No Sample has ever exceeded or come close to the Copper Action Level in Reading Building)

ND = Not Detected or Less Than 1 ug/L (< 1 ppb)

10_Public Buildings & Fountains

PWS Code #: 3246000

Lead Levels Found in Building Tap Samples Updated 07/31/2016

Town Location	Tap Location	Fixture Type	Fixture ID #	DEP #	06/21/16	06/21/16	07/07/16	07/20/16	07/20/16		
					First Draw ug/L	30 Sec Flush ug/L	Remediation	First Draw ug/L	30 Sec Flush ug/L		
Reading DPW Garage	In Hall by Lunch Room	Water Fountain	DPW-HALL-WF1	001	ND	ND					
Reading DPW Garage	Men's Bathroom	Sink Faucet	DPW-MBAT-SK1	002	3.9	ND					
Reading DPW Garage	Men's Bathroom	Sink Faucet	DPW-MBAT-SK2	003	3.2	ND					
Reading DPW Garage	Women's Bathroom	Sink Faucet	DPW-WBAT-SK1	004	ND	ND					
Reading Fire Station (Main St)	Men's Garage Bay Bathroom	Sink Faucet	FRM-BAYB-SK1	005	ND	ND					
Reading Fire Station (Main St)	Handicap Bathroom	Sink Faucet	FRM-HBTH-SK1	006	ND	ND					
Reading Fire Station (Main St)	Kitchen	Sink Faucet	FRM-KICH-SK1	007	1.1	ND					
Reading Fire Station (Main St)	Men's Bathroom	Sink Faucet	FRM-MBTH-SK1	008	ND	ND					
Reading Fire Station (Main St)	Women's Bathroom	Sink Faucet	FRM-WBTH-SK1	009	5.9	ND					
Reading Fire Station (Woburn St)	Kitchen	Sink Faucet	FRW-KICH-SK1	010	3.3	ND					
Reading Fire Station (Woburn St)	Men's Bathroom	Sink Faucet	FRW-MBAT-SK1	011	11.9	2.1					
Reading Fire Station (Woburn St)	Women's Bathroom	Sink Faucet	FRW-WBAT-SK1	012	3.0	ND					
Reading Fire Station(Woburn St)	Men's Garage Bay Bathroom	Sink Faucet	FRW-BAYB-SK1	013	51.5	4.0	Replace Faucet	1.2	ND		
Reading Police Station	1st Floor Men's Bathroom	Sink Faucet	PLC-1HAL-SK1	014	ND	ND					
Reading Police Station	1st Floor Women's Bathroom	Sink Faucet	PLC-1HAL-SK2	015	1.1	ND					
Reading Police Station	2nd Floor Hallway	Water Fountain	PLC-2NFL-WF1	016	ND	ND					
Reading Police Station	Basement Hallway	Water Fountain	PLC-BHAL-WF1	017	ND	ND					
Reading Police Station	Communication's Room #2	Sink Faucet	PLC-CRM2-SK1	018	10.1	ND					
Reading Police Station	Dispatch Bathroom	Sink Faucet	PLC-DSPC-SK1	019	1.8	ND					
Reading Police Station	Dispatch Kitchenette	Sink Faucet	PLC-DSPC-SK2	020	ND	ND					
Reading Police Station	Kitchen	Sink Faucet	PLC-KICH-SK1	021	1.2	ND					
Reading Police Station	Lobby	Water Fountain	PLC-LOBY-WF1	022	ND	ND					
Reading Police Station	2nd Floor Men's Bathroom	Sink Faucet	PLC-MB2F-SK1	023	2.0	ND					
Reading Police Station	Lobby Men's Bathroom	Sink Faucet	PLC-MBLB-SK1	024	2.8	ND					
Reading Police Station	Men's Fitness Room	Sink Faucet	PLC-MFIT-SK1	025	6.3	ND					
Reading Police Station	2nd Floor Women's Bathroom	Sink Faucet	PLC-WB2F-SK1	026	ND	ND					
Reading Police Station	Lobby Women's Bathroom	Sink Faucet	PLC-WBLB-SK1	027	1.9	ND					
Reading Police Station	Women's Fitness Room	Sink Faucet	PLC-WFIT-SK1	028	7.1	ND					
Reading Police Station	Communication's Room	Sink Faucet	PLC-COM1-SK1	029	4.1	ND					
Reading Senior Center	Activities Room	Water Fountain	SCN-ACTR-WF1	030	ND	ND					
Reading Senior Center	Art Room	Sink Faucet	SCN-AROM-SK1	031	2.4	ND					
Reading Senior Center	Kitchen	Sink Faucet	SCN-KICH-SK1	032	ND	ND					
Reading Senior Center	Kitchen	Sink Faucet	SCN-KICH-SK2	033	5.9	ND					
Reading Senior Center	Kitchen	Sink Faucet	SCN-KICH-SK3	034	1.3	ND					
Reading Senior Center	Kitchen	Sink Faucet	SCN-KICH-SK4	035	2.8	ND					
Reading Town Hall	2nd Floor Hallway	Water Fountain	TNH-2NDF-WF1	036	3.9	ND					
Reading Town Hall	Clerk's Kichenette	Sink Faucet	TNH-CLRK-SK1	037	10.2	ND					
Reading Town Hall	Public Service's Kichenette	Sink Faucet	TNH-DPCF-SK1	038	1.8	ND					
Reading Town Hall	DPW Women's Bathroom	Sink Faucet	TNH-DPWB-SK1	039	ND	ND					
Reading Town Hall	DPW Men's Bathroom	Sink Faucet	TNH-DPMB-SK1	040	10.8	ND					

Reading Town Hall	Main Lobby	Water Fountain	TNH-MNLB-WF1	041	ND	ND					
Reading Town Hall	Records Area	Sink Faucet	TNH-RECD-SK1	042	ND	ND					
Reading Town Hall	In Hall by Recreation	Water Fountain	TNH-RECH-WF1	043	ND	ND					
Reading Town Hall	In Hall by Recreation	Water Fountain	TNH-RECH-WF2	044	1.1	ND					
Reading Town Hall	Lunchroom	Sink Faucet	TNH-LNCR-SK1	045	2.7	ND					
Reading Town Hall	Women's Bathroom	Sink Faucet	TNH-WBAT-SK1	046	ND	ND					
Reading Town Hall	Men's Bathroom	Sink Faucet	TNH-MBAT-SK1	047	ND	ND					