

Reading Public Fountains 2019 LCCA Lead in Water Testing Results

MassDEP Action Level (AL) for Lead in water is: Greater Than 15 ug/L (Reading set an AL of 12 ug/L)

MassDEP Action Level (AL) for Copper in water is: Greater Than 1300 ug/L (No Sample has ever exceeded or come close to the Copper Action Level in Reading Schools)

ND = Not Detected or Less Than 1 ug/L (< 1 ppb)

11_Public_Fountains

PWS Code #: 3246000

Lead Levels Found in Public Fountain Samples Updated 08/06/2019

Fountain Name	Location	Fixture Type	Fixture ID #	DEP #	06/22/16 First Draw ug/L	08/06/19 First Draw ug/L	08/06/19 30 Sec Flush ug/L			
Bancroft Playground	Bancroft Ave	Water Fountain	RWF-BANC-WF1	001	2.6	2.3	ND			
Bancroft Tennis Court	Bancroft Ave	Water Fountain	RWF-BANC-WF2	002	1.4	ND	ND			
Birch Meadow	Birch Meadow Dr. @ Arthur B. Lord	Water Fountain	RWF-BMDW-WF1	003	2.8	7.7	5.1			
Barrows Back Field	16 Edgemont Ave	Water Fountain	RWF-BRWS-WF1	004	1.0	2.6	1.2			
Hunt Field	Eaton St.	Water Fountain	RWF-HUNT-WF1	005	4.8	3.4	2.4			
Memorial Park	Harrison St.	Water Fountain	RWF-MEMO-WF1	006	2.3	3.0	3.7			
Parker Bottom Field	45 Temple St.	Water Fountain	RWF-PKMS-WF1	007	4.9	3.4	8.4			
Town Commons	Main St. @ Woburn St.	Water Fountain	RWF-SQUA-WF1	008	3.7	5.5	1.3			
Sturges Park Main	Pineridge Rd.	Water Fountain	RWF-STRG-WF1	009	1.8	ND	ND			
Sturges Park Backstop	Pineridge Rd.	Water Fountain	RWF-STRG-WF2	010	n/a	ND	ND			
Symmons Way Field	Symmonds Way	Water Fountain	RWF-SYMM-WF1	011	3.3	1.5	2.0			
Washington Park Ballfield	Washington St.	Water Fountain	RWF-WASH-WF1	012	1.7	1.9	ND			
Washington Park Playground	Washington St.	Water Fountain	RWF-WASH-WF2	013	2.6	ND	ND			
Joshua Eaton Playground	356 Summer Ave	Water Fountain	RWF-JOEA_WF1	014	n/a	ND	ND			
Killam Playground	333 Charles St.	Water Fountain	RWF-KILM_WF1	015	n/a	2.6	ND			